

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0559:134 Page 1 of 1

CATEGORY: Control Unit (Non High Rise)

LISTEE: Silent Knight Security, 7550 Meridian Circle, Maple Grove, MN 55369
Contact: Brian Foltz *(763) 493-6400

DESIGN: Models SK-2224, SK-4224 and SK-6324* Fire Alarm Control Units. Power limited, automatic, manual, local, waterflow and sprinkler supervisory service. Refer to listee's data sheet for additional detailed product description and operational considerations.
System components:

SK-2224/SK-4224/SK-6324	Main Board
SK-2884	Serial Driver Board
SK-2865, SK-2880, SK-2866	Remote Annunciators
SK-2104	Digital Dialer

RATING: 120 VAC Primary, 24 VDC Secondary

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, electrical rating and UL label.

APPROVAL: Listed as fire alarm control unit for use with separately listed electrically and functionally compatible initiating and indicating devices.

This control unit can generate the temporal code pattern fire alarm signal as required per NFPA 72, 1996 Edition. Refer to listee's Installation Manual for details.

NOTE: For Fire Alarm Verification Feature (delay of alarm signaling), the Retard/Reset/Restart period shall be 30 seconds or less.

*Rev. 06-21-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

MAY 16, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager